

Cementex Rubber Goods Stamp Changes

New formatting of stamping makes it simple to know maximum use voltage for both AC and DC systems and the date the rubber good was tested.

Old Format

Cementex Products, Inc.
Maximum USE Voltage: 500V
Date Tested:

Cementex Products, Inc.
Maximum USE Voltage: 1,000V
Date Tested:

Cementex Products, Inc.
Maximum USE Voltage: 7,500V
Date Tested:

Cementex Products, Inc.
Maximum USE Voltage: 17,000V
Date Tested:

Cementex Products, Inc.
Maximum USE Voltage: 26,500V
Date Tested:

Cementex Products, Inc.
Maximum USE Voltage: 36,000V
Date Tested:

New Format

Cementex Products, Inc.
Max Use: 500VAC | 750VDC
Date Tested: _____

Cementex Products, Inc.
Max Use: 1,000VAC | 1,500VDC
Date Tested: _____

Cementex Products, Inc.
Max Use: 7,500VAC | 11,250VDC
Date Tested: _____

Cementex Products, Inc.
Max Use: 17,000VAC | 25,500VDC
Date Tested: _____

Cementex Products, Inc.
Max Use: 26,500VAC | 39,750VDC
Date Tested: _____

Cementex Products, Inc.
Max Use: 36,000VAC | 54,000VDC
Date Tested: _____