## Testing and CARIL Recertification Services

In order to maintain compliance with requirements established by OSHA 1910.137(b)(2)(vii), NFPA 70E® and CSA Z462; Rubber Insulating Products shall be subjected to periodic electrical tests in accordance with the ASTM standard identified in the chart below.

As an Accredited Member of The Association of North American Independent Laboratories for Protective Equipment Testing (NAIL for PET), you are assured that testing of these protective devices is performed as it should be. Cementex insures all testing devices are properly calibrated and all tests are performed as required by the corresponding ASTM Standard.



Rubber Insulating Equipment	When to Test	Governing Standard for Test Voltage
Blankets	Before first issue; every 12 months thereafter†	ASTM F 479
Covers	If insulating value is suspect	ASTM F 478
Gloves	Before first issue; every 6 months thereafter	ASTM F 496
Line Hose	If insulating value is suspect	ASTM F 478
Sleeves	Before first issue; every 12 months thereafter	ASTM F 496

## Rubber Insulating Product Testing

CPT-GLV.......Blanket Testing, All Classes (36" x 36")
CPT-SLV......Sleeve Testing, All Classes
CPT-LH.....Line Hose, Per 6 foot length
CPT-OS......Overshoe and Boot Testing
CPT-MAT......Shielding Material Testing

## Hot Stick and Insulated Equipment Testing

## Torque Wrench Recalibration and Recertification Services\*

\*Torque Wrench recalibrations and recertification services are not subject to discounts.

Testir